

**DWQMS Management Review Committee
LaSalle Public Works**

Date: December 20, 2019

Location: LaSalle Public Works Building Board room

Participants: Rob Mackie Superintendent of Water/Wastewater, QMS Rep.
 Lena Petros Manager of Water/Wastewater, QMS Rep.
 Jay Wigle Water/Wastewater Leader

Distribution: All Participants, Owner Representative

Prepared by: Lena Petros – Manager of Water/Wastewater, QMS Rep.

Item	Description	Action	Resp. Person	Due Date
1	Acceptance of Agenda	Accepted		
2	Acceptance of Minutes of Previous Meeting	Accepted		
3	Incidents of regulatory non-compliance: MOE Inspection Report dated August 12, 2019 was reviewed during September 13, 19 meeting.	NAR		
4	Incidents of adverse drinking water tests: This item was review at Sep 13, 2019 meeting	NAR		
5	Deviations from critical control limits and response actions: No deviation from critical control limits	NAR		
6	The effectiveness of the Risk Assessment Process: Please refer to item 20	NAR		

Item	Description	Action	Resp. Person	Due Date
7	<p>Internal and third-party audit results:</p> <p>Internal audit report dated September 26, 2019 was reviewed during Nov 26, 19 Water & Wastewater Committee meeting.</p> <p>Third-party Audit report dated Dec 6, 2019 will be reviewed during January 28, 2020 Water & Wastewater Committee meeting.</p>	QMS Rep. to respond to all internal and external audit findings and make appropriate revisions	Lena Petros	2 nd quarter of 2020
8	<p>Results of emergency response testing:</p> <p>This item was review at Sep 13, 2019 meeting</p>	NAR		
9	<p>Operational performance:</p> <p>This item was review at Sep 13, 2019 meeting</p>	NAR		
10	<p>Raw water supply and drinking water quality trends:</p> <p>This item was review at Sep 13, 2019 meeting</p>	NAR		
11	<p>Follow-up on action items from previous Management Reviews:</p> <p>Sep 13, 2019 meeting:</p> <p>Noisy meters complaints</p> <p>Parkway mainline valve labeling</p> <p>Meeting with Town of Tecumseh regarding Howard feed to Tecumseh took place on</p>	<p>Purchase different types of residential meter to try-out</p> <p>Superintended of Water/Wastewater to follow-up</p> <p>QMS Rep. to follow</p>	<p>Lena Petros and Rob Mackie</p> <p>Rob Mackie</p> <p>Lena</p>	<p>1st quarter 2020</p> <p>3rd quarter 2020</p> <p>2nd quarter</p>

Item	Description	Action	Resp. Person	Due Date
	<p>September 3, 2019</p> <p>No RP backflow on third hydrant hookup</p> <p>Electronic work order system still in progress, issues with mobile application, meeting with City Wide Works scheduled on Sep 20, 18 to go over deficiencies.</p> <p>Town owned pressure testing and chlorinating equipment</p> <p>2018 municipal elections</p> <p>Issues with City Wide Works mobile application.</p> <p>The risk assessment review meeting took place as part of this meeting and changes to Procedure 2 table 1 is required</p>	<p>up with Director of Public Works on the new agreement for capital contribution of twin 30” replacement</p> <p>Contact supplier</p> <p>Follow up with City Wide Works on full implementation</p> <p>Purchase necessary equipment</p> <p>Re-endorsement of OP</p> <p>New mobile application reliability</p> <p>Updates as per item 17</p>	<p>Petros</p> <p>Rob Mackie</p> <p>Lena Petros</p> <p>Rob Mackie</p> <p>Lena Petros</p> <p>Lena Petros</p> <p>Lena Petros</p>	<p>of 2020</p> <p>Completed 2019</p> <p>Completed 2019</p> <p>Completed 2019</p> <p>Completed 2019</p> <p>Completed 2019</p> <p>Completed 2018</p>
12	<p>The status of management action items identified between reviews:</p> <p>None</p>	NAR		
13	<p>Changes that could affect the QMS:</p> <p>None</p>	NAR		
14	<p>Consumer feedback:</p> <p>This item was review at Sep 13, 2019 meeting</p>	NAR		
15	<p>The resources needed to maintain the QMS:</p> <p>None</p>	NAR		
16	<p>The results of the infrastructure review:</p>			

Item	Description	Action	Resp. Person	Due Date
	This item was review at Sep 13, 2019 meeting	NAR		
17	Operational Plan currency, content and updates: Current Operational Plan revision # 17 version 2.0	NAR		
18	Staff suggestions: None	NAR		
19	Review of List of Essential Supplies/Services/Emergency Contacts for the Town of LaSalle The list was reviewed, no updates required	NAR		
20	Risk assessment and risk assessment outcome, verification and update The risk assessment review meeting took place as part of Sep 13, 19 meeting and no change were required	NAR		

NAR - No Action Required

OP – Operational Plan

IA – Internal Audit

EA – External Audit