

Coulter Services
180 Whiting St Ingersoll, Ontario N5C 3B5
Phone # 647-746-0044

Customer:	Town of LaSalle	Service Date:	December 18 2019
Address:	6585 Disputed Road	Manufacture:	Sensus
	Town of LaSalle	Size/Type:	5/8" SRII
Occupant:		Registration:	M3
Contact Name:	Rob Mackie	Remote type:	
Telephone #:	5199694143	Serial No:	75309020
Meter Location:	In Shop	I.D. No:	71913569

Meter Running on Arrival	Y	N	Chamber	Y	N
Meter Sealed on Arrival	Y	N	Two Man Job	Y	N
Bypass Sealed on Arrival	Y	N	Bypass	Y	N
If No, was it open	Y	N	Test Port	Y	N
Meter Running on Departure	Y	N	Strainer	Y	N
Meter&Valves Sealed on Departure	Y	N	Broken Valves Tagged	Y	N

	As Found	After Service
HF Out	2510.9767	2511.50265
HF In		
LF Out		
LF In		

Pretest Results						Post Calibration Results					
LPM	Quantity Del.	High	Med	Low	%	LPM	Quantity Del.	High	Med	Low	%
56.78	391.5	391.7			100.05	56.781	0	0			#DIV/0!
7.571	38.5	38.5			100.00	7.5708	0.0	0.0			#DIV/0!
0.95	39.5	38.0			96.20	0.9464	0.0	0.0			#DIV/0!
Meter Runs at Minimum Flow						Meter Runs at Minimum Flow					
				Y						Y	

Notes/Comments:

Accuracy Requirements: High Flow 98.5-101.5%, Medium Flow 98.5-101.5%, Low Flow 95-101.5%

Meter Passed

Travel To	Time In	Time Out	Travel Back	Total hours	Crew
N/A	N/A	N/A	N/A		Taylor H

Job Complete ~~Y~~ N

Signature: Taylor H

Thank you for your business!